



PEARSON KENT MCKINLEY RAAF ENGINEERS
13300 W 98TH STREET LENEXA, KS 66215

January 14, 2020

19.637

Mr. Joe Frogge
City of Lee's Summit
220 SE Green
Lee's Summit, MO 64063

Re: Simply Threads
893 Lemans Lane, Lee's Summit, MO 64082

Joe,

Please see below for our responses to your comments dated January 13, 2020:

1. 2018 IBC 1016.2 Egress through intervening spaces. Egress through intervening spaces shall comply with this section. Item 5. Egress shall not pass through kitchens, storage rooms, closets, or spaces used for similar purposes.
Action Required: Remove exit sign directing egress through storage room.
Response: PKMR gives permission for the exit sign to be crossed out on the plans.

Regards,

PKMR ENGINEERS

Will Kent, PE
Principal

