

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192753
Address: 1108 NE GOSHEN CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|----------------------------|
| Piers/Caissons Inspection - Residential | Khanh Nguyen | Failed | Thursday, January 16, 2020 |

Corrective Action Required:
1 Misc PIERS MUST BE MIN 36" DEEP BELOW GRADE

Comments: