



MEMO via fax

Date: January 14, 2020

To: City of Lee's Summit

From: Dan Webster, AIA dan@websterarchitects.com

Copy:

Attachments:

Subject: Permit Number PRRES20192617 2013 NE Bluestone Drive

For structural purposes, only 2 studs are required between the windows. (We had called out 3 studs for trim purposes and the builder has elected to trim out the windows differently.)

