CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20190679 Address: 222 SW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspecti	on:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial		Michael Harkins	Partial	Thursday, January 16, 2020
Partial Co	orrection:			
1	Misc	OK TO COVER WHEN READY EXTERIOR SHEAR WALL SHEATHING FULL HEIGHT COMPLETE PERIMETER		
Informat	ional:			
2	Misc	HOLD DOWNS COMPLETE 1ST & 2nd FLOOR EXTERIOR WALLS		
		2nd floor offices metal stud framing excluding kitchen & restrooms & office near stairway not complete		
		1st floor interior shear wall NW & SE walls screw pattern 3" perimeter 12" field to 10' ceiling		

Comments: