

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191317
Address: 1712 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Failed	Thursday, January 16, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- finish vent and hood above stove- outlets at south side of kitchen need to be Gfci protected, cannot locate where they are tripped too or there is no power- address cut floor joist in basement, SE corner. Missed at all rough- install gutters and finish water drainage- sod, water discharge must be 36" from foundation, final grade |
|---|------|--|

Comments: