

DEVELOPMENT SERVICES

Building Permit - Residential	Permit No: PRRES20193316
Project Title:	Date Issued: January 16, 2020
Work Desc: NEW SINGLE FAMILY	

Project Address:

1626 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

KEVIN HIGDON CONSTRUCTION, LLC

P O BOX 847

Permit Holder:

Legal Description: NAPA VALLEY 3RD PLAT---LOT 123

Parcel No: 69720071500000000

LEES SUMMIT, MO 64063

County: JACKSON

Activities Included for this Project:

zNew Single Family, Right of Way, License Tax, License Tax Credit, Deck - Covered Residential, Driveway Permit, Sidewalk Permit,

Construction Type: Type VB	Occupancy: RESIDENTIAL, ONE- AND	Zoning District: PMIX
(Unprotected)	TWO-FAMILY	
	Valuation: \$277,538.00	

Residential Area:		
Residential, Living Area	1625	
Residential, Un-Finished basements	257	
Residential, Finished basements	1215	
Residential, Decks	186	
Residential, garage	725	

Commercial Area	2746 sq. ft.

Inches of Days	VD	r	Data: Ian 10 2020
rissuea Bv:	KB		Date: Jan 16. 2020

THIS PERMIT IS ISSUED IN RELIANCE UPON INFORMATION SUBMITED BY THE APPLICANT. THE BUILDING OFFICIAL MAY SUSPEND OR REVOKE WHENEVER THE PERMIT IS ISSUED IN ERROR, OR ON THE BASIS OF INCORRECT INFORMATION SUPPLIED, OR IN VIOLATION OF ANY ADOPTED CODE, CITY ORDINANCE OR REGULATIONS.

NOTICE: THE DISPOSAL OF DEMOLITION WASTE IS REGULATED BY THE DEPARTMENT OF NATURAL RESOURCES UNDER CHAPTER 260 RSMO. SUCH WASTE, IN TYPES AND QUANTITIES ESTABLISHED BY THE DEPARTMENT, SHALL BE TAKEN TO A DEMOLITION LANDFILL OR A SANITARY LANDFILL FOR DISPOSAL.

CONDITIONS

One or more divisions have conditions that have not been addressed during the review period. The outstanding conditions provided below shall be met as indicated during the construction period.

Plot Plan Review		

1	Sidewalks with dimensions must be provided on the plot plan.	Sidewalks with dimensions must be provided on the plot plan.		
NO SIDE	NO SIDEWALK SHOWN ON PLAT PLEASE CLARIFY.			
2 master	Drainage swales (where required); show spot elevations within the swale as required to conform to the approved er drainage plan (if applicable), must be provide			
3	A as-graded plot plan per Section 7-160, Code of Ordinances, is requi	A as-graded plot plan per Section 7-160, Code of Ordinances, is required prior to occupancy.		
4	Basement egress location(s) and elevation of the lowest adjacent gra	Basement egress location(s) and elevation of the lowest adjacent grade must be provided on the plot plan.		
Constru	struction Drawings must be the same layout as the plot plan. They appear	flipped. please correct this.		
5	Add 100 year flood elevation detail.			
6	The Basement floor elevation and basement type (e.g. full/standard,	daylight, walk-out, etc.)		
MDP SH	SHOWS STANDARD BASEMENT AND YOUR PURPOSING A DAYLIGHT. PLE	ASE ADD		
Resider	idential Plan Review			
1	Provide square footage of living area, garage area, unfinished basem	ent area, etc (IRC Section R304)		
FINISHE UNFINIS	1ST FLOOR SQ FT IS DIFFERENT PLEASE CLARIFY FINISHED BASEMENT SQ FT IS OFF PLEASE CLARIFY UNFINISHED BASEMENT SQ FT IS OFF PLEASE CLARIFY GARAGE SQ FT IS OFF PLEASE CLARIFY.			
2	Designate R-value(s) for floors, walls, ceilings, roof/ceilings. (LSCO 7-	802)		
INSULA	INSULATION DETAIL REFERS TO 2012 IRC AND SHOULD REFERENCE 2018.			
3	ALL NOTES SHOULD REFERENCE 2018 IRC BUILDING CODE NOT 2012.			
Plannir	nning Review (RES)			
1	Please label all exterior materials			
Planning Review (RES)				
1	Please label all exterior materials			
Signatu Applica	nature of licant: Date:JANUA	ARY 16, 2020		
Print na	t name: Company Nam	e:KEVIN HIGDON		