

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172507
Address: 213 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|----------------------------|
| Occupancy Inspection - Codes Commercial | Mark Harding | Failed | Thursday, January 16, 2020 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | Water- failed see seperate report Fire failed see report Site inspecitons approved by steve robbins Planning OK for COFO Codes- >>Label main disconnect >>complete dryer vents on exterior. >>Complete addresses. >> install fan in sprinkler room in basement. >>install required ADA fixtures in bathroom, under sink height is lower than 27", install required vertical grab bar and seat for shower. |
|---|------|--|

Comments: