

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20193031	Date:	January 17, 2020
Project Title:	ADVANCED SURGICAL ASSOCIATES - LEE'S SUMMIT SURGICAL CENTER	Applicant:	
Location:	2861 NE INDEPENDENCE AVE, Unit:205, LEES SUMMIT, MO 64064	JAYHAWK FIRE SPRINKLER CO INC 12030 S HEDGE LANE TERRACE OLATHE, KS 66061	
Type of Work:		Primary: (913) 422-3770	
Occupancy Group:	B		
Description:	TENANT FINISH FOR SURGICAL CENTER		
Construction Type:	Type IIB (Unprotected)		
Map Page:	175R		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic Test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.