

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192649
Address: 2548 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Friday, January 17, 2020

Informational:

1	Misc	GARAGE PORTAL FRAMING NAIL PATTERN
---	------	------------------------------------

Corrective Action Required:

2	Misc	PROVIDE PFH PORTAL FRAMING GARAGE DOOR PER PLAN DOUBLE BOTTOM PLATE W/ 5/8 ANCHOR BOLTS - ADDRESS 9 1/2 LVL LAUNDRY ROOM OVER NOTCHED - PROVIDE SOLID SHIMS AT HINGES AND DEADBOLT EXTERIOR DOORS- PROVIDE BONDING SCREW SERVICE ENTRY PANEL-
---	------	--

Comments: