

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192215
Address: 3340 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Friday, January 17, 2020

Corrective Action Required:

1	Misc	- complete dryer exhaust - complete heat flue - protect electrical at bottom plate in laundry room - complete bathroom exhaust fans - solid block double walls in basement, insulation not allowed at those spans - protect electrical home run going to electrical panel - security blocking needed for rear basement door - fire block electrical penetrations in air plenum, outside of basement bathroom
---	------	--

Ok to insulate

Comments: