

## ANALYTICAL REPORT

February 06, 2019

Work Order: 1B90176

Page 1 of 3

Report To
Joe Starlin City of Lee's Summit - Public Works Dept. 220 SE Green Street Lees Summit, MO 64063

Work Order Information
Date Received: 02/05/2019 8:00AM Collector: Salinas, Daniel Phone: (816) 969-7428 PO Number: Routine Analysis

Project : Redford Construction

Project Number: North Park Village 2nd

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
<b>1B90176-01</b> 5+90.04 NE				Matrix:Drink Wtr		Collected: 02/04/19 09:18	
Total Coliforms	<1.0 MPN/100ml	1.0	1CB0113	9223B-QT	CLJ	02/05/19 10:00	
E. Coli	<1.0 MPN/100ml	1.0	1CB0113	9223B-QT	CLJ	02/05/19 10:00	
<b>1B90176-02</b> 18+00 SE				Matrix:Drink Wtr		Collected: 02/04/19 09:34	
Total Coliforms	<1.0 MPN/100ml	1.0	1CB0113	9223B-QT	CLJ	02/05/19 10:00	
E. Coli	<1.0 MPN/100ml	1.0	1CB0113	9223B-QT	CLJ	02/05/19 10:00	
<b>1B90176-03</b> 9+85.46 SW				Matrix:Drink Wtr		Collected: 02/04/19 09:09	
Total Coliforms	<1.0 MPN/100ml	1.0	1CB0113	9223B-QT	CLJ	02/05/19 10:00	
E. Coli	<1.0 MPN/100ml	1.0	1CB0113	9223B-QT	CLJ	02/05/19 10:00	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.  
220 SE Green Street  
Lees Summit, MO 64063

February 06, 2019

Page 2 of 3

Work Order: 1B90176

## Certified Analyses included in this Report

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr		
	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

  

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2019
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2019
MO-KC	Missouri Department of Natural Resources	140	04/30/2019
SIA1X	Iowa Department of Natural Resources	95	02/01/2019

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson  
Project Manager

PAGE: 1 of 1

016 626-0170

[illegible]

Remarks:

Date: / /

Time: 08:00

Rec'd: *[Signature]* 2/4/19  
1400