

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20190111
Address: 4829 NE JAMESTOWN DR, LEES SUMMIT, MO 64064
Inspected On: Tuesday, January 21, 2020
Inspected By: Khanh Nguyen
Expiration Date: 2/21/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Tuesday, January 21, 2020

Corrective Action Required:

1	Misc	-Lawn irrigation permit -Driveway not approved on record -Install sewer tracer box -Provide min six inches clearance from pex to furnace connector
---	------	---