CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20193356 Address: 4401 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Brandon Kalwei	Failed	Tuesday, January 21, 2020

Corrective Action Required:

1 Misc

Drain tile needs to be set around foundation, all underslab plumbing is covered up. Uncover and call in when ready

Comments: