

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190138
Address: 2240 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Partial	Tuesday, January 21, 2020

Corrective Action Required:

1 Misc

ABOVE CEILING OK:
-RM 103-107; 113

REMAINING ROOMS: SUPPORT GRID; COMPLETE CONDENSATE LINES FROM VRF UNITS; COMPLETE VRF DISCHARGE LINE TO APPROVED POINT OF DISPOSAL

Comments: