

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20192339

Address: 2861 NE INDEPENDENCE AVE, Unit:201, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                     | Inspector:   | Outcome: | Date:                     |
|---------------------------------|--------------|----------|---------------------------|
| <b>Above Ceiling Inspection</b> | Khanh Nguyen | Partial  | Tuesday, January 21, 2020 |

Partial Correction:

1 Misc

ABOVE CEILING OK TO COVER:

-RM 200.25 & 200.24; 200.06-15; 200.16, 200.17-22; 200.35 AND CORRIDOR OUTSIDE

\*\*CAULK ALONG SMOKE WALL; VENT DRYER DUCT ABOVE RM 200.23 TO OUTSIDE

**Comments:**