

**DEVELOPMENT SERVICES**

**PLAN REVIEW CONDITIONS**

January 22, 2020

SBC ARCHITECTURE  
3009 ELMIRA CT  
INDEPENDENCE, MO 64057

Permit No: PRCOM20193705  
Project Title: BAKERS DISTRIBUTION  
Project Address: 2716 NE MCBAINE DR 2716 NE MCBAINE DR, LEES SUMMIT, MO 64064  
Parcel Number: 203931  
Location / Legal: I-470 BUSINESS & TECHNOLOGY CENTER LOT 13A  
Description:  
Type of Work: NEW TENANT FINISH  
Occupancy Group: STORAGE, MODERATE HAZARD  
Description: TENANT FINISH FOR OFFICE/WAREHOUSE

***Revisions Required***

***One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

**Fire Plan Review**

**Reviewed By: Michael Weissenbach**

**Rejected**

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

(Action Required)

Any modifications to the fire alarm system, provide three sets of PE stamped shop drawings.

2. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

(Verified At Inspection)

Address all exterior doors to the space.

**DEVELOPMENT SERVICES**

3. 2018 IFC 506.1- Where required. Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type and shall contain keys to gain necessary access as required by the fire code official.

(Informational Purposes)

A Knoxbox is not required for the individual space. The shell building will have one placed by the FDC.

4. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

(Action Required)

Any modifications to the fire sprinkler system, provide three sets of PE stamped shop drawings.

5. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

7. (Action Required)

Provide a detailed plan showing racks/storage in the warehouse area.

1/22/2020

Provide a detailed plan showing racks/storage in the warehouse area.

8. 2018 IFC 1010.1.9 Door operations. Except as specifically permitted by this section, egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

(Verified At Inspection)

**Building Plan Review**

**Reviewed By: Joe Frogge**

**Pending**

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

1/22/20 - acknowledged in letter.

2. This tenant finish permit is associated with an incomplete shell permit.

Action required: Comment is for informational purposes. Occupancy will not be granted for the tenant prior to completion of shell permit.

1/22/20 - acknowledged in letter.

**Licensed Contractors**

**Reviewed By: Joe Frogge**

**Approved**

**DEVELOPMENT SERVICES**

*The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.*