

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192339
Address: 2861 NE INDEPENDENCE AVE, Unit:201, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Wednesday, January 22, 2020

Corrective Action Required:

1	Misc	-Approval from Fire required -Resolve condition for shell permit TCO -Reconnect vent line above sterile area -Install strobes above restrooms
---	------	--

Comments: