

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191578
Address: 1804 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, January 22, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Post Address- GFCI electrical outlets required in garage- Bottom sash of widow behind exterior door by kitchen needs to be tempered glass.- Security screws, 3" required on both hinge and strike side of exterior door by kitchen.- Install guardrail on west side of front porch- Seal exterior lights at garage doors- Seal all exterior penetrations- Complete exterior water drainage- 3' discharge from foundation required at all downspouts and sump pump discharge.- Final grade and sod required- Submit as graded plot plan for review prior to sodding |
|---|------|--|

Comments: