

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192019
Address: 1533 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Thursday, January 23, 2020

Corrective Action Required:

1	Misc	- Loose stud on pantry wall - Fireblock gap properly by basement window - Loose stud by basement window - Damaged ductwork in basement bathroom and west bedroom basement - Incomplete ductwork at furnace, labeled as lower level great room
---	------	---

Comments: