

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192072
Address: 1537 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Thursday, January 23, 2020

Corrective Action Required:

1	Misc	- Double up overnotched stud, single car garage wall - Foundation bolts not secured with nuts or aligned with plate north wall basement - Address cut floor joist east side basement - Address cut floor joist north wall basement
---	------	---

Comments: