

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20173051
Address: 1980 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Partial	Thursday, January 23, 2020

Partial Correction:

1	Misc	-ELEVATOR SHAFT WALL-OK: 3RD FL N&W&E WALL AND 2ND FL N,W,&E WALL 1" GLASS BOARD -MECHANICAL SHAFT WALL-OK: 3RD FL W WALL 1" GLASS BOARD-OK -NORTH WALL MECHANICAL SIDE OK TO COVER ONLY. 1" GLASS. : WEST & EAST MECHANICAL SHAFT HARD LID 1ST LAYER 1" GLASS BOARD OK :
---	------	---

Comments: