

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192573
Address: 1209 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Thursday, January 23, 2020

Corrective Action Required:

1	Misc	-Fire approval is required -Install permanent occupant load signage -Install anti-backflow device for ice maker -Sink trap weir cannot be above the vent connection -Install EM egress lighting and exit signs per plan
---	------	---

Comments: