

DAILY FIELD REPORT

CLIENT:	Pearl Real Estate Company 919 N East Street Indianapolis, Indiana 46202	PROJECT:	Summit of West Pryor Apartments Lee's Summit, Missouri
ATTN:	Brad Richey	DATE:	12/12/19
WEATHER:	Sunny	CFS PERSONNEL:	M. Simpson
TEMPERATURE:	35-55	REPORT #:	19-1125-dr- 28

DEVIATION FOUND: NO

DEVIATION CORRECTED:

ORIGINAL DEVIATION DATE:

TYPE OF SERVICE BEING PERFORMED

MASONRY	GROUT
MASONRY	REINFORCING STEEL
CONCRETE	PLACEMENT
CONCRETE	REINFORCING STEEL

WORK ACCOMPLISHED THIS DATE:

· Monitored placement of grout and inspected reinforcing steel at A/4.3 to 1.8, elevation 96.8 to 100.8 (grouted solid.)

· Reinforcing steel verified to be in compliance with plans and specifications.

• Monitored placement of concrete for Ftgs from J/4.8 - 1.5

• One set of 4 test cylinders were cast. Slump and temperature met job requirements.

• Reinforcing steel verified to be in compliance with plans and specifications.