

DAILY FIELD REPORT

CLIENT:	Pearl Real Estate Company 919 N East Street Indianapolis, Indiana 46202	PROJECT:	Summit of West Pryor Apartments Lee's Summit, Missouri
ATTN:	Brad Richey	DATE:	12/3/19
WEATHER:	Sunny	CFS PERSONNEL:	M. Simpson
TEMPERATURE:	30-50	REPORT #:	19-1125-dr- 21

TYPE OF SERVICE BEING PERFORMED

SOILS	FOUNDATIONS
MASONRY	GROUT
MASONRY	REINFORCING STEEL

DEVIATION FOUND: NO

DEVIATION CORRECTED:

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- · Monitored placement of grout and inspected reinforcing steel at B.2 -12 to 10.2 A, elevation 100.4 to 103.4 T.O.W
- One set of 4 grout prisms and one set of 3 mortor cubes were cast. Slump verified to be within specifications.
- Reinforcing steel verified to be in compliance with plans and specifications.
- · Inspected footings for 3.1 line/ C, D, E, F, G & G.9
- All footings met required bearing capacity and size. Reinforcing steel found to be in compliance with plans and specifications.