

1100 W Cambridge Circle Drive

Suite 700

Kansas City, Kansas 66103

913.627.9040

2121 Moodie Road Lawrence, Kansas 66046 2011 NW Topeka Blvd Topeka, Kansas 66608

785.856.9600 785.270.6447

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company PROJECT: Summit of West Pryor

919 N East Street Apartments

Indianapolis, Indiana 46202 Lee's Summit, Missouri

ATTN: Brad Richey DATE: 1/6/20

CFS

WEATHER: Sunny PERSONNEL: G. Kenyon

TEMPERATURE: 30-50 REPORT #: 19-1125-dr- 42

TYPE OF SERVICE BEING PERFORMED

SOILS COMPACTION MONITORING DEVIATION FOUND: NO

CONCRETE PLACEMENT DEVIATION CORRECTED:

CONCRETE CYLINDER PICK UP ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- · Monitored placement and compaction of fill for Interior plumbing trench back fill.
- Monitored placement of concrete at exterior footing 11.6 on A-line. Footing was undermined at this location by drain pipe routed underneath footing. The contractor formed & shored the area to be poured back. One yard of concrete was used to pour this area.
- · Cylinder pick up of set 29.