



1100 W Cambridge Circle Drive, Suite 700
 Kansas City, Kansas 66103
 913.627.9040

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
 919 N East Street
 Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
 Apartments
 Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 12/13/19

WEATHER: Sunny

CFS
 PERSONNEL: M. Simpson

TEMPERATURE: 35-55

REPORT #: 19-1125-dr- 29

TYPE OF SERVICE BEING PERFORMED

MASONRY GROUT

DEVIATION FOUND: NO

MASONRY REINFORCING STEEL

DEVIATION CORRECTED:

CONCRETE PLACEMENT / REINFORCING STEEL

ORIGINAL DEVIATION DATE:

CONCRETE CYLINDER PICK UP

WORK ACCOMPLISHED THIS DATE:

- Monitored placement of grout and inspected reinforcing steel at A/4.3 to 1.8, elevation 96.8 to 100.8 TOW
- Reinforcing steel verified to be in compliance with plans and specifications.
- Monitored placement of concrete for Ftgs. J-1.5 to D.9-1
- One set of 4 test cylinders were cast. Slump and temperature met job requirements.
- Reinforcing steel verified to be in compliance with plans and specifications.
- Cylinder pick up of set 2009.