



1100 W Cambridge Circle Drive, Suite 700
Kansas City, Kansas 66103
913.627.9040

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 12/9/19

WEATHER: Overcast

CFS
PERSONNEL: M. Simpson

TEMPERATURE: 40-48

REPORT #: 19-1125-dr- 25

TYPE OF SERVICE BEING PERFORMED

MASONRY GROUT

DEVIATION FOUND: NO

MASONRY REINFORCING STEEL

DEVIATION CORRECTED:

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- Monitored placement of grout and inspected reinforcing steel at A line/4.2 TO 5.6, (97.4 - 103.75 AFF) Wall is grouted solid.
- Reinforcing steel verified to be in compliance with plans and specifications.