



1100 W Cambridge Circle Drive, Suite 700
Kansas City, Kansas 66103
913.627.9040

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 12/10/19

WEATHER: Sunny

CFS
PERSONNEL: M. Simpson

TEMPERATURE: 22-38

REPORT #: 19-1125-dr- 26

TYPE OF SERVICE BEING PERFORMED

CONCRETE PLACEMENT

DEVIATION FOUND: NO

CONCRETE REINFORCING STEEL

DEVIATION CORRECTED:

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- Monitored placement of concrete for Walls at G.10-12 to 10.1-J & footing Tie in to elevator Wall @ 7.5-A
- One set of 4 test cylinders were cast. Slump and temperature met job requirements.
- Reinforcing steel verified to be in compliance with plans and specifications.