



### **PLAN REVIEW CONDITIONS**

January 28, 2020

THE WILSON GROUP  
1606 W MAIN ST  
GREENWOOD, MO 64034

Permit No: PRCOM20200178  
Project Title: LEE'S SUMMIT FIRE HEADQUARTERS  
Project Address: 207 SE DOUGLAS ST, LEES SUMMIT, MO 64063  
Parcel Number: 61340200600000000  
Location: HOWARDS 1ST ADD TO L S S1/2 OF LT 7 & ALL OF LTS 8 & 9 BLK 17 & ALL VAC ALLEY LY ADJ  
TO LOTS 8, 9, & 4 BLK 17  
Type of Work: ALTERATION COMMERCIAL  
Occupancy Group:  
Description: KITCHEN REMODEL

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

**Fire Plan Review**

**Reviewed By: Michael Weissenbach**

**Approved with Conditions**

1. (Informational Purposes)

Guardian suppression system required over gas range.

NOTE: This will be owner supplied.

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***