

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192077
Address: 1525 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, January 28, 2020

Corrective Action Required:

1	Misc	STRAP TOP PLATE AT LAUNDRY VENT - SECURE GAS LINE AT FIRE PLACE - SEAL GAS LINE UPWARD PENETRATION AT FIREPLACE - SEAL CANTILEVER UNDER FIREPLACE - PROVIDE TJC37 HANGERS MASTER & PATIO PER PLAN - PROVIDE SOLID BLOCKING BETWEEN JOIST UNDER KITCHEN ISLAND PER PLAN -
---	------	--

Comments: