



PLAN REVIEW CONDITIONS

January 29, 2020

DESIGN CLUB INC
30519 S LONETREE ROAD
HARRISONVILLE, MO 64701

Permit No: PRCOM20200191
Project Title: HALLAM OFFICE BUILDING - 2ND FLOOR TENANT SUITES
Project Address: 1225 NE DOUGLAS ST, LEES SUMMIT, MO 64086
Parcel Number: 52910150400000000
Location: MAPLE TREE PLAZA 2ND PLAT---LOT 3 (EX PT IN ROW)
Type of Work: NEW TENANT FINISH
Occupancy Group: BUSINESS
Description: TENANT FINISH FOR FOUR INDIVIDUAL TENANT SPACES WITH SHARED RESTROOM AND COFFEE BAR

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

(Verified At Inspection)

The new addition will need to be addressed:

Lower level 1237 NE Douglas Unit 101 (Vacant) front and back doors

Lower Level 1237 NE Douglas Unit 105 (Brilliant) front and back doors

Upper Level 1237 NE Douglas Unit 201 on back door

Signage on front of building: Entrance to Unit 201 in rear of building

2. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be

along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

(Verified At Inspection)

Provide 1 2A10BC Fire Extinguisher

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.