

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182604
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Friday, January 31, 2020

Partial Correction:

1 Misc

OK TO FOAM AND INSULATE AT:
ABOVE CEILING AT: 4TH FLOOR: LEFT WING;

WALL FURRED-OUT TO ENCLOSE ELECTRICAL CABLES AND INSULATION AT GOLF ROOM

Partial Correction:

2 Misc

OK TO COVER WALLS AND CEILINGS AT:

LEFT WING: COMPLETE INCLUDING RC CHANNEL

CENTER SECTION: 4TH FLOOR INCLUDING RC CHANNEL AT CEILINGS ONLY; 3RD FLOOR; 2ND FLOOR; 1ST FLOOR UNIT 110; 1ST FLOOR MECH ROOM W/ DOORS #C16 & C17;

RIGHT WING: 4TH FLOOR;

Partial Correction:

3 Misc

OK TO COVER WHEN READY:
LIGHT-GAUGE STEEL FRAMED CEILING FUR-DOWNS AT: (1)228; (1)229;
LEFT WING: 4TH FLOOR;
CENTER SECTION: 4TH FLOOR; 2ND FLOOR UNITS 211, MOTHER-IN-LAW, 217;

SPACE ABOVE BOTTOM CHORD OF JOISTS AT: BA IN MOTHER-IN-LAW UNIT @
RIGHT WING; VESTIBULES AT (1)211 & (1)217;

Comments: