

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190679
Address: 222 SW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Tuesday, February 04, 2020

Corrective Action Required:

1	Misc	IFGC 404.8: METALLIC PIPING EXPOSED TO WEATHER MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS. PAINT 100% OF STEEL PIPE INCLUDING AT SUPPORTS. SEE GAS PIPING AT METER AND ROOFTOP.
---	------	--

Corrective Action Required:

2	Misc	BEFORE FINAL INSPECTION CHECK SPACING OF ROOFTOP PIPING SUPPORTS.
---	------	---

Comments: