

**DEVELOPMENT SERVICES**

**PLAN REVIEW CONDITIONS**

February 05, 2020

Stephen Guindon  
1631 Alhambra Blvd. Suite 100  
Sacramento, CA 95816

Permit No: PRCOM20200228  
Project Title: CVS PHARMACY - HEALTHHUB  
Project Address: 3351 SW 3RD ST, LEES SUMMIT, MO 64081  
Parcel Number: 62420989800000000  
Location / Legal: NEW LONGVIEW COMMERCIAL DISTRICT 1ST PLAT LOT 41----LOT 41  
Description:  
Type of Work: ALTERATION COMMERCIAL  
Occupancy Group: MERCANTILE  
Description: INTERIOR ALTERATIONS INCLUDING NEW HEALTH CLINIC

***Revisions Required***

***One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

**Licensed Contractors**

**Reviewed By: Joe Frogge**

**Rejected**

1. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

2. Lee's Summit Code of Ordinance, Section 7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the name of the licensed general contractor.

**Building Plan Review**

**Reviewed By: Joe Frogge**

**Rejected**

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

---

**DEVELOPMENT SERVICES**

Action required: Comment is for informational purposes.

2. All plans submitted for review on or after April 1, 2019 shall be designed to the requirements of the 2018 International Building Code, 2018 International Mechanical Code, 2018 International Plumbing Code, 2018 International Fuel Gas Code, 2018 International Fire Code, 2017 National Electric Code and the ICC/ANSI A117.1-2017 as amended and adopted by the City of Lee's Summit.

Action required: Revise Code Data on sheet G4 to show correct code year which is 2018. (given the minor nature of comment we can correct by hand under direction from architect)

3. A code analysis shall be provided which includes but is not limited to occupancy type, occupant load, construction type, actual area, height and floors, allowable area, height and floors, and the codes to which the project is designed.

Action required: Revise code data on sheet G4 to show correct building construction type which is 5B. (given the minor nature of comment we can correct by hand under direction from architect)

**Fire Plan Review**

**Reviewed By: Michael Weissenbach**

**Approved with Conditions**

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions. (Informational Purposes)

Any modifications to the fire alarm system, provide three sets of PE stamped shop drawings.

2. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation. (Informational Purposes)

Any modifications to the fire sprinkler system, provide three sets of PE stamped shop drawings.

3. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. (Informational Purposes)

Call (816)969-1300 to schedule testing if modifications were made.

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***