CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182604

Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Rated Assembly Inspection John Borns Partial Thursday, February 06,

2020

Partial Correction:

1 Misc OK TO COVER WHEN READY 5/8" TYPE X GWB AT FIREWALL:

LEFT WING: 4TH FLOOR:

WEST FACE: 1ST AND 2ND LAYERS ABOVE CEILING; BELOW CEILING 1ST AND

2ND LAYERS; FULL HEIGHT FIRESTOPPED

EAST FACE: 1ST LAYER ABOVE CEILING; 2ND LAYER HUNG & FIRESTOPPED;

BELOW CEILING 1ST & 2ND LAYERS;

3RD FLOOR:

WEST FACE: BELOW CEILING: 1ST LAYER; 2ND LAYER FULL HEIGHT; EAST FACE

1ST LAYER;

2NDLAYER CORRIDOR,

2ND FLOOR:

WEST FACE: 1ST LAYER FULL HEIGHT; 2ND LAYER ABOVE CEILING;

1ST FLOOR: WEST FACE: UNIT SIDE OF FLOOR TWO LAYERS FULL HEIGHT + FIRESTOP; GARAGE/ CORRIDOR/GARAGE SIDE OF FLOOR 1ST & 2ND LAYERS;

4' SECUROCK SHEATHING PROJECTION OUTSIDE SOUTH BUILDING WALL --

TWO LAYERS FULL HEIGHT.

RIGHT WING:

4TH FLOOR: BOTH FACES ABOVE CEILING 1ST LAYER; 2ND LAYER ABOVE

CEILING B/F; FIRESTOPPED;

BACKSIDE: BELOW CEILING 1ST & 2ND LAYERS;

3RD FLOOR: BOTH FACES ABOVE CEILING 1ST & 2ND LAYERS; BELOW CEILING

1ST & 2ND LAYERS;

2ND FLOOR: BOTH FACES ABOVE CEILING 1ST & 2ND LAYERS;

1ST FLOOR: BOTH FACES ABOVE CEILING 1ST & 2ND LAYERS; 1ST LAYER BELOW

CEILING;

4' SECUROCK SHEATHING PROJECTION OUTSIDE SOUTH BUILDING WALL -- TWO LAYERS FULL HEIGHT.

Partial Correction:

4 Misc

OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLIES AT STAIRWELL WALLS/CEILINGS:

STAIRWELL 1:

1ST FLOOR: 1ST LAYER; 2ND LAYER; 2ND FLOOR: 1ST LAYER; 2ND LAYER;

3RD FLOOR: 1ST LAYER; 2ND LAYER; BACKSIDE 1ST & 2ND LAYERS;

4TH FLOOR: 1ST LAYER; 2ND LAYER @ WELL FACE BELOW TOWER; BACKSIDE

1ST & 2ND LAYERS;

CEILINGS HIGH & LOW 1ST LAYER; 2ND LAYER; 3RD LAYER + HAT CHANNEL; 4TH

LAYER

STAIRWELL 2:

1ST FLOOR: 1ST LAYER; 2ND LAYER;

2ND FLOOR: 1ST LAYER; 2ND LAYER @ 2 OF 3 WALLS;

3RD FLOOR: 1ST LAYER; 2ND LAYER;

4TH FLOOR: 1ST LAYER INSIDE FACE; 2ND LAYER BOTH FACES; WALLS ABOVE CEILING AT TOWER 1ST AND 2ND LAYERS; WALLS BELOW CEILING AT TOWER 1ST & 2ND LAYERS; CEILINGS HIGH & LOW 1ST & 2ND LAYERS; 4TH RC, 4TH

LAYER

STAIRWELL 3:

1ST FLOOR: WELL FACE 1ST LAYER, 2ND LAYER; CORR / UNIT 110 FACE 1ST

LAYER + 2ND LAYER; LOW CEILING ONE LAYER;

2ND FLOOR: WELL FACE 1ST LAYER, 2ND LAYER; BACKSIDE 2 LAYERS; LOW

CEILING 1ST LAYER;

3RD FLOOR: WELL FACE 1ST LAYER, 2ND LAYER; BACKSIDE 1ST LAYER

4TH FLOOR: WELL FACE 1ST LAYER, 2ND LAYER; BACKSIDE 1ST & 2ND LAYER; TOP OF TOWER: 1ST & 2ND LAYERS ABOVE CLG @ W WALL; CEILING AND WALLS BELOW CEILING 1ST & 2ND LAYERS; HIGH & LOW CEILINGS 3 LAYERS +

HAT CHANNEL, 4TH LAYER;

NOTE: FIRESTOPPING WHERE PVC PIPE INTERRUPTS GWB IS SUBJECT TO APPROVAL WHEN COMPLETED. USE ONLY LISTED FIRECAULK;

Partial Correction:

5 Misc

OK TO COVER WHEN READY FRAMING, THEN 5/8" MOLD-RESISTANT FIRECODE X GWB @ ELEVATOR SHAFTS:

ELEVATOR #1:

FRAMING - FLOORS 4,3,2,1

SPACES BETWEEN JOISTS AT BACKSIDE

:

1ST FLOOR: 1ST & 2ND LAYERS

WALL INTERIOR FACE: FULL HEIGHT 1ST LAYER

CEILING: 1ST LAYER

; 2ND LAYER; 3RD LAYER + HAT CHANNEL; 4TH LAYER

2ND FLOOR: 1ST 2nd layer walls

3RDFLOOR: 1ST 2nd layer walls; BACKSIDE & ADJACENT SHEARWALL 1ST &

2ND LAYERS;

4TH FLOOR: 1ST 2nd layer walls WELL FACE; BACKSIDE 1ST & 2ND LAYERS;

ELEVATOR #2:

WALL INTERIOR FACE: FULL HEIGHT 1ST LAYER; 2ND LAYER

CEILING: 1ST LAYER; 2ND LAYER; 3RD LAYER + HAT CHANNEL; 4TH LAYER

EXTERIOR FACE:

4TH FLOOR 1ST LAYER + 2ND LAYER FULL HEIGHT 3RD FLOOR 1ST LAYER; 2ND LAYER FULL HEIGHT

2ND FLOOR: 1ST LAYER FULL HEIGHT; 2ND LAYER FULL HEIGHT 1ST FLOOR: 1ST LAYER FULL HEIGHT; 2ND LAYER FULL HEIGHT

SPACES BETWEEN JOISTS AT BACKSIDE

:

1ST FLOOR: 1ST & 2ND LAYERS

Partial Correction:

9 Misc FIREWALLS AND SHEARWALLS AT CENTER SECTION 1ST FLOOR.

OK TO COVER WHEN READY: 1ST LAYER;

Comments: