

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20184050
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|-----------------------------|
| DE - Erosion Sediment Control (ESC) Inspection | John DiMauro | Failed | Thursday, February 06, 2020 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | There is an area along SW KLINE AVE where the silt fence was knocked down and is allowing silt and mud to wash onto the property behind it at 3200 SW RAGAN CT. Please clean the silt and mud from the property at 3200 SW RAGAN CT and make corrections to the erosion control devices as soon as possible to control the silt and mud from washing off site and onto the surrounding properties. Photos of area are uploaded. |
|---|------|---|

Comments: