

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192572
Address: 1980 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	Michael Harkins	Partial	Thursday, February 06, 2020

Corrective Action Required:

1	Misc	WASTE&VENT PLUMBING PRESSURE TEST: 3RD FL NORTH BRANCH OK 2/6/20 3rd floor 2 gauges steady at 5 psi
---	------	--

Comments: