CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191998

Address: 1321 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Failed Friday, February 07,

Residential 2020

Corrective Action Required:

1 Misc -As-graded plot plan is required prior to sodding

-Provide landscaping at rear per city ordinance

-Final grade, sod, downspout and sump pump extensions

-Make sure that the sewer tracer wire and port are installed and available at

grade level

-Seal exterior lights. Front entry lights not meeting security code

-Handrail not continuous for the entire upper floor stair flight. FYI: the winder

tread is not a landing

-Install water hammering arrestor for dish washer

-Fb garage wall penetrations

-Provide afci protection per NEC 210.12

-Install breaker lock for circuit feeding the kitchen hood

Comments: