

**CITY OF LEE'S SUMMIT**  
**Development Services Department**  
**220 SE Green Street**  
**Lee's Summit, MO 64063**  
**(816) 969-1200      FAX (816) 969-1201**

# **Temporary**

## **Certificate of Occupancy**

---

**Permit #:**                **PRRES20191317**  
**Address:**              **1712 SW MERRYMAN DR, LEES SUMMIT, MO 64082**  
**Inspected On:**        **Friday, February 07, 2020**  
**Inspected By:**        **Patrick Schonfeldt**  
**Expiration Date:**    **4/7/2020 12:00:00 AM**

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Temporary C of O	Friday, February 07, 2020

**Corrective Action Required:**

- |   |      |   |
|---|------|---|
| 1 | Misc | - install gutters and finish water drainage<br>- sod, water discharge must be 36" from foundation, final grade<br>- guard rail required at front porch, more than 30" |
|---|------|---|