

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192670
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Saturday, February 08, 2020

Partial Correction:

1	Misc	WALLS DESIGNATED SW-1 & SW-2 OK TO COVER ON OUTSIDE FACE. HOLD-DOWN LOCATIONS AT EXTERIOR WEST WALL SOUTH SEGMENT TO BE MODIFIED PER DOOR OPENING REVISIONS. HOLD-DOWN INSTALLATION SUBJECT TO APPROVAL BY SPECIAL INSPECTOR.
---	------	--

Comments: