

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20182652  
Address: 2100 SW LADDERBACK DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Hydrostatic Test</b>	John DiMauro	Partial	Monday, February 10, 2020

Informational:

1 Misc

I observed the hydrostatic pressure test for Water Lines 1&3.

Line 1 held 163 psi for two hours. Test Passed.

Line 3 held 155 psi for two hours. Test Passed.

The crew plans to return after lunch to hydro test Water Line 2.

**Comments:**