

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182604
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, February 10, 2020

Partial Correction:

1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT FIREWALL & SHEARWALLS:

RIGHT WING:

2ND FLOOR: BOTH FACES ABOVE CEILING 1ST & 2ND LAYERS; BELOW CEILING 1ST & 2ND LAYERS;

1ST FLOOR: BOTH FACES ABOVE CEILING 1ST & 2ND LAYERS; BELOW CEILING 1ST & 2ND LAYERS;

Partial Correction:

2 Misc

OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLIES AT STAIRWELL WALLS/CEILINGS:

STAIRWELL 1:

1ST FLOOR: SHAFT 1ST LAYER, 2ND LAYER; BACKSIDE 1ST LAYER

2ND FLOOR: SHAFT 1ST LAYER, 2ND LAYER; BACKSIDE 1ST & 2ND LAYERS

STAIRWELL 2:

1ST FLOOR: 1ST LAYER; 2ND LAYER;

2ND FLOOR: 1ST LAYER; 2ND LAYER @ 2 OF 3 WALLS;

3RD FLOOR: 1ST LAYER; 2ND LAYER;

4TH FLOOR: 1ST LAYER INSIDE FACE; 2ND LAYER BOTH FACES; WALLS ABOVE

CEILING AT TOWER 1ST AND 2ND LAYERS; WALLS BELOW CEILING AT TOWER 1ST & 2ND LAYERS; CEILINGS HIGH & LOW 1ST & 2ND LAYERS; 4TH RC, 4TH LAYER

STAIRWELL 3:

1ST FLOOR: WELL FACE 1ST LAYER, 2ND LAYER; CORR / UNIT 110 FACE 1ST LAYER + 2ND LAYER; LOW CEILING ONE LAYER;

2ND FLOOR: WELL FACE 1ST LAYER, 2ND LAYER; BACKSIDE 2 LAYERS; LOW CEILING 1ST LAYER;

3RD FLOOR: WELL FACE 1ST LAYER, 2ND LAYER; BACKSIDE 1ST LAYER

4TH FLOOR: WELL FACE 1ST LAYER, 2ND LAYER; BACKSIDE 1ST & 2ND LAYER;

TOP OF TOWER: 1ST & 2ND LAYERS ABOVE CLG @ W WALL; CEILING AND WALLS BELOW CEILING 1ST & 2ND LAYERS; HIGH & LOW CEILINGS 3 LAYERS + HAT CHANNEL, 4TH LAYER;

NOTE: FIRESTOPPING WHERE PVC PIPE INTERRUPTS GWB IS SUBJECT TO APPROVAL WHEN COMPLETED. USE ONLY LISTED FIRECAULK;

Partial Correction:

3 Misc

OK TO COVER WHEN READY FRAMING, THEN 5/8" MOLD-RESISTANT FIRECODE X GWB @ ELEVATOR SHAFTS:

ELEVATOR #1:

WALL INTERIOR FACE: FULL HEIGHT 1ST LAYER

CEILING: 1ST LAYER

; 2ND LAYER; 3RD LAYER + HAT CHANNEL; 4TH LAYER

2ND FLOOR: SHAFT 1ST, 2nd layer walls; BACKSIDE 1ST & 2ND LAYERS

Partial Correction:

4 Misc

FIREWALLS AND SHEARWALLS AT CENTER SECTION 1ST FLOOR.

OK TO COVER WHEN READY: 1ST & 2ND LAYERS

Partial Correction:

5 Misc

OK TO COVER WHEN READY CEILING & COMMON/CORRIDOR WALL RATED ASSEMBLIES:

RIGHT WING:

4TH FLOOR;

Comments: