

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192670
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Failed	Monday, February 10, 2020

Corrective Action Required:

2 Misc

PERIMETER WALLS:

ANCHORAGE OF EXTERIOR WALL SILL PLATE IBC 2308.6: MIN TWO BOLTS PER PIECE; ONE WITHIN 12" OF ENDS OF EACH PIECE; PER DRAWINGS, 4` MAX SPACING BETWEEN BOLTS

Comments: