

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20193219	Date:	February 10, 2020
Project Title:	EXOS PHYSICAL THERAPY - LEE'S SUMMIT SURGICAL CENTER	Applicant:	
Location:	2861 NE INDEPENDENCE AVE, Unit:100, LEES SUMMIT, MO 64064	JAYHAWK FIRE SPRINKLER CO INC	12030 S HEDGE LANE TERRACE OLATHE, KS 66061
Type of Work:		Primary:	(913) 422-3770
Occupancy Group:	B		
Description:	TENANT FINISH FOR PHYSICAL THERAPY		
Construction Type:	Type IIB (Unprotected)		
Map Page:	175R		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. (Informational Purposes)
Update records showing 2016 NFPA and 2018 I-Series.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.