

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20193057
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Pipe	John Jackson	Partial	Friday, December 27, 2019

Informational:
1 Misc Contractor installed approximately 100' of PR. STM 24" HP between A1 and A2.

Informational:
2 Approximately 180' of 24" HP was installed on Onsite Storm Line 200 Sta. 0+00 to 1+79.27 & 45' of SCH. 40 PVC Sta. 1+79.27 to 2+24.76.

Informational:
3 30" Nyloplast D.B. was installed @ Sta 1+79.27 and 24" Nyloplast D.B. @ Sta. 2+24.76 .

Comments: