## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20182604

Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Rated Assembly Inspection John Borns Partial Tuesday, February 11,

2020

Partial Correction:

1 Misc OK TO COVER WHEN READY 5/8" TYPE X GWB AT FIREWALL & SHEARWALLS:

**RIGHT WING:** 

3RD FLOOR: BOTH FACES ABOVE CEILING 1ST & 2ND LAYERS; BELOW CEILING

1ST & 2ND LAYERS;

2ND FLOOR: BOTH FACES ABOVE CEILING 1ST & 2ND LAYERS; BELOW CEILING

1ST & 2ND LAYERS;

1ST FLOOR: BOTH FACES ABOVE CEILING 1ST & 2ND LAYERS; BELOW CEILING

**1ST & 2ND LAYERS:** 

Partial Correction:

2 Misc OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLIES AT

STAIRWELL WALLS/CEILINGS:

STAIRWELL 1:

2ND FLOOR: SHAFT 1ST LAYER, 2ND LAYER; BACKSIDE 1ST & 2ND LAYERS 1ST FLOOR: SHAFT 1ST LAYER, 2ND LAYER; **BACKSIDE 1ST & 2ND LAYERS** 

STAIRWELL 2:

1ST FLOOR: 1ST LAYER; 2ND LAYER; BACKSIDE 1ST & 2ND LAYERS

2ND FLOOR: 1ST LAYER; 2ND LAYER @ 2 OF 3 WALLS; BACKSIDE 1ST & 2ND

**LAYERS** 

3RD FLOOR: 1ST LAYER; 2ND LAYER; BACKSIDE 1ST & 2ND LAYERS

NOTE: FIRESTOPPING WHERE PVC PIPE INTERRUPTS GWB IS SUBJECT TO

APPROVAL WHEN COMPLETED. USE ONLY LISTED FIRECAULK;

Partial Correction:

3 Misc OK TO COVER WHEN READY FRAMING, THEN 5/8" MOLD-RESISTANT FIRECODE

X GWB @ ELEVATOR SHAFTS:

ELEVATOR #1:

2ND FLOOR: SHAFT 1ST, 2nd layer walls; BACKSIDE 1ST & 2ND LAYERS

1ST FLOOR: BACKSIDE 1ST & 2ND LAYERS

Partial Correction:

5 Misc OK TO COVER WHEN READY CEILING & COMMON /CORRIDOR WALL RATED

ASSEMBLIES: RIGHT WING:

4TH FLOOR; 3RD FLOOR;

1ST FLOOR: CORRIDOR WALLS UNIT/STOR RM FACE 1ST & 2ND LAYERS;

**Comments:**