

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20182652
Address: 2100 SW LADDERBACK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Hydrostatic Test	John DiMauro	Passed	Tuesday, February 11, 2020

Informational:

1 Misc

I observed the hydrostatic pressure test for Water Lines 1&3.

Line 1 held 163 psi for two hours. Test Passed.

Line 3 held 155 psi for two hours. Test Passed.

The crew plans to return after lunch to hydro test Water Line 2.

Informational:

2 Misc

I observed the hydro test for Water Line 2.

The line held at 163 psi for two hours. Test Passed.

Comments: