

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192550
Address: 1511 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, February 11, 2020

Corrective Action Required:

1	Misc	Provide anchor bolts within 12" of plate break -basement bedroom #3, under windows, rear corner red room - Provide missing nuts & washers bottom plate - Provide draft stop bed #4 wall at garage - Seal upward penetration gas line fireplace - Maintain gravel filter driveway -
---	------	--

Comments: