

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20192670  
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Partial	Tuesday, February 11, 2020

Partial Correction:

1 Misc

PERIMETER WALLS:

**ANCHORAGE OF EXTERIOR WALL SILL PLATE APPROVED. NO OTHER ISSUES ON EXTERIOR WALL FRAMING OR EXTERIOR SHEATHING.**

**Comments:**