

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20191897  
Address: 3200 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                      | Inspector:     | Outcome: | Date:                      |
|--|----------------|----------|----------------------------|
| <b>DE - Water Line - Construction Inspection</b> | Ronald Paynter | Partial  | Tuesday, February 11, 2020 |

Informational:

|   |      |  |
|---|------|--|
| 1 | Misc | Andrew from Weers is installing the water line. They started on line 4 and laid 125 ft of C900 water pipe. RP 10-24-19 |
|---|------|--|

Informational:

|   |      |   |
|---|------|---|
| 2 | Misc | Weers finally found the existing water line 16 ft below grade. Water lines 4 and 1 are suppose to tee into this line. Told them to hold off until Water and Schlagel can come up with a plan on how to proceed. RP 10-25-19 |
|---|------|---|

Informational:

|   |      |  |
|---|------|--|
| 3 | Misc | Meet with Jeremy and Ryan from Water and Shawn from BSM. They agreed to abandon the water line in place that was buried 16 ft. The abandoned line will be capped off at both ends. Weers will install a 12 inch and 8 inch valve at the 12 inch tee. RP 10-29-19 |
|---|------|--|

Informational:

|   |      |   |
|---|------|---|
| 4 | Misc | Andrew's crew abandoned the old line and set 30 ft of new line as replacement. They also set 80 ft of 12 inch water pipe, along with 12 x 12 tee, 12 inch valve and 8 inch valve. The also set road crossings for lines 1, 2 and 4. They filled the road crossings with flowable fill. RP 11-1-19 |
|---|------|---|

Informational:

|   |      |   |
|---|------|---|
| 5 | Misc | Dwayne's crew from Weers Construction installed the water lines 1, 2, 3, and 4. We left the temporary fire hydrants in on lines 1 and 3 because the weren't installed as temporary fire hydrants. We also found buried gated valves by the fire hydrants on lines 1 and 3. We left those in place for |
|---|------|---|

connections to the existing water lines. RP 2-10-20

**Comments:**